



DISTRICT BOARD

Megan Clark
Rabi Elias
Russ Greenfield
Craig K. Murray
Judy Schriebman

DISTRICT ADMINISTRATION

Chris DeGabriele,
Interim General Manager
Michael Cortez,
District Engineer
Mel Liebmann,
Plant Manager
Susan McGuire,
Administrative Services Manager
Greg Pease,
Collection System/Safety Manager

ADDENDUM NO. 1

Date: July 13, 2018
Project: **Sewer Main Rehabilitation 2018**
Job No.: 19200-01

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents, and shall become a part of the Contract Documents dated June 2018.

1. Refer to Vol. 1, Page 1-1, NOTICE INVITING SEALED BIDS, Paragraph 3: Delete mandatory requirement for the pre-bid meeting. However, this Project still requires Bidders to submit a notarized copy of a Site Visit Affidavit to be submitted with the Bid. See required form under Bidding Requirements section of the Contract Documents. Special site visits may be scheduled 24 hours in advance with the Assistant Engineer, telephone number 415-472-1033, extension 29, a minimum of five (5) working days before bid opening.
2. CLARIFICATIONS: Unless authorized by the District representative in the field, no hydraulic or pneumatic bursting device that breaks apart existing pipe may be positioned inside existing manhole during trenchless rehabilitation.
3. CLARIFICATIONS: Refer to Volume 4 – Drawings, Sheet 6 of 22, Flexible Manhole Connection Type 2. Assume existing manhole bases are not formed during construction, no additional compensation shall be made for over poured manhole bases.
4. CLARIFICATIONS: Refer to Volume 4 – Drawings, Sheet 13 of 22: Line 1 – Garden Ave currently has a shared lateral serving multiple properties. Contractor shall provide a separate lateral connection and lower lateral for each property.

This addendum consists of one (1) page including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 2-5, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District: Bidder: _____

Michael P. Cortez, PE, District Engineer
Tel. No. (415) 472-1033, ext. 18

(Authorized Signature)

(Date)