



DISTRICT BOARD

Megan Clark
Rabi Elias
Craig K. Murray
Judy Schriebman
Crystal Yezman

DISTRICT ADMINISTRATION

Mike Prinz,
General Manager
Michael Cortez,
District Engineer
Mel Liebmann,
Plant Manager
Vacant,
Administrative Services Manager
Greg Pease,
Collection System/Safety Manager

ADDENDUM NO. 2

Date: August 13, 2020
Project: **AIR RELEASE VALVE & VAULT REPLACEMENTS**
Job No.: 20200-01

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents, and shall become a part of the Contract Documents dated July 2020.

1. **Clarifications:** Recoat all exposed piping per specifications below. Painting of valve pit interior walls is not required.
2. Coating Specifications for Ductile Iron Pipe and Appurtenance:
 - a. Surface Preparation:
 - i. Steel Surface Preparation: SSSPC-SP10 Near White Blast Cleaning.
 - ii. Ductile Iron Surface Preparation: Prepare all surfaces as per NAPF 500-03 - Uniformly abrasive blast the entire exterior surface using abrasive to an NAPF 500-03-04 with a minimum angular anchor profile of 1.5 mils.
 - b. Coating System:
 - i. Steel Surface:
 1. Primer: Hi-Build Epoxoline II L69 at 4.0 – 6.0 mils dft
 2. Intermediate: Hi-Build Epoxoline II L69 at 4.0 – 6.0 mils dft
 3. Finish: Hi-Build Epoxoline II L69 at 4.0 – 6.0 mils dft
 - ii. Ductile Iron Surface:
 1. Primer: Hi-Build Epoxoline II L69 at 4.0 – 6.0 mils dft
 2. Intermediate: Hi-Build Epoxoline II L69 at 4.0 – 6.0 mils dft
 3. Finish: Hi-Build Epoxoline II L69 at 4.0 – 6.0 mils dft
3. **Clarifications:** Delete requirements of recoating of Air Release Valve (ARV) metal supports in the contract documents. ARV metal supports shall be 316 SS.

This addendum consists of one (1) page including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 2-1, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District: Bidder: _____

Michael P. Cortez, PE, District Engineer (Authorized Signature) _____ (Date)
Tel. No. (415) 472-1033, ext. 18