



DISTRICT BOARD

Megan Clark
Rabi Elias
Russ Greenfield
Craig K. Murray
Judy Schriebman

DISTRICT ADMINISTRATION

Chris DeGabriele,
Interim General Manager
Michael Cortez,
District Engineer
Mel Liebmann,
Plant Manager
Susan McGuire,
Administrative Services Manager
Greg Pease,
Collection System/Safety Manager

ADDENDUM NO. 6

Date: October 29, 2018
Project: **MARINWOOD-HWY 101 TRUNK SEWER UNDERCROSSING
EMERGENCY REPAIR**
Job No.: **11200-03**

To: All Planholders and Prospective Bidders

This addendum consists of three (3) page(s) including this page. Acknowledge receipt of this addendum in the space provided on page 11, Proposal and Bid Schedule, of the Contract Documents, and by signing in the space provided below. Submit original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District: Bidder: _____

Michael P. Cortez, PE, District Engineer
Tel. No. (415) 472-1033, ext. 18

(Authorized Signature)

(Date)

The following changes and/or clarifications are hereby made to the Contract Documents, and shall become a part of the Contract Documents dated September 2018.

1. Replace the bid form issued in Addendum No. 4 with the attached revised bid form. Bid item #4 has been revised to require a minimum of four (4) point repairs. Actual quantity may vary and final payment will be adjusted accordingly per unit price shown in the bid form. In addition, a separate bid item for sheeting, shoring, and bracing has been added to the bid form.

SCHEDULE OF UNIT PRICE AND LUMP SUM BID ITEMS:

1. For the trenchless rehabilitation of the 18" Asbestos Bonded Corrugated (ABC) trunk sewer by (select one):

- a. ____ Cured-in-Place Pipe (CIPP) lining;
- b. ____ Fold and Form Pipe (FFP) lining;

complete in place as shown and specified: 420 LF multiplied by \$_____ per lineal foot, at the Extended Total of:

\$ _____
(In figures)

2. For the pre-construction CCTV inspection to determine if the existing 18" ABC trunk sewer is suitable for the trenchless rehabilitation selected in Bid Item 1 above, at the Lump Sum price of:

\$ _____
(In figures)

3. For the post-construction CCTV inspection, at the Lump Sum price of:

\$ _____
(In figures)

4. For point repairs, complete in place, as shown and specified: four (4) each multiplied by \$_____ per each, at the Extended Total of:

\$ _____
(In figures)

5. For bypass pumping, complete in place, as shown and specified, at the Lump Sum price of:

\$ _____
(In figures)

6. For Caltrans encroachment permit fees (\$984), vegetation clearing and grubbing of the existing earthen ditch, offsite disposal of excavated materials, and other requirements, complete in place, as shown and specified, at the Lump Sum price of:

\$ _____
(In figures)

7. For sheeting, shoring, and bracing, at the Lump Sum price of:

\$ _____
(In figures)

8. For mobilization, demobilization, general conditions, and incidentals not included in Bid Items 1 thru 7; however, are necessary for the successful completion of the project, at the Lump Sum price of:

\$ _____
(In figures)

TOTAL BASE BID, BASIS OF AWARD (SUM OF BID ITEMS 1 thru 8):

\$ _____
(In figures)